

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. / Noida / S.M. / Jal-I / 2023 / 136

Dated: 16/5/2023

It is certified that an inspection team headed by Sanjay Parashar, Sr. Manager
(Name of Officers with designation) from Jal div. - I

(Name of Department/ Office) inspected the Drinking water & Sanitation facilities at
DPS, Sec-122, Noida

(Name & Address of the school) on 15/05/23.....(date of inspection) and found that the
DPS, Sec-122 Noida.....(Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of 01 (one) year.

Signature with Seal: [Signature]

Name : Sanjay Parashar

Designation : Senior Manager

Name & Address of the Office / Department :

To

DPS, Sec-122 Noida

(Name & Address of the Institution)



[Signature]
Principal
DPS Sector-122
Noida-UP

[Signature]
Secretary
The Delhi Public School Society
F-Block, East of Kailash
New Delhi-110065



GHAZIABAD TESTING LABORATORIES PVT. LTD.

TEST REPORT

Issued To,
M/s. Delhi Public School.
Sec.-122 Noida.

Report No. : 100-230921-11
Report Date : 26/09/2023
Sample Received On : 21/09/2023
Analysis Date : 21/09/2023
Report Prepared On : 26/09/2023
Sampled By : Customer

Sample Description : RO Water for Drinking water
Condition of the sample on receipt : Received in good condition
Letter No. : DPS122N/Estate/23/162

Dated:- 21/09/2023

Page 1 of 2

S. No.	Parameters	Unit	Test Method	Result	Standard Limit as per IS:10500-2012
Physical & Chemical Parameters					
1	pH Value at 25°C	-	IS: 3025 (P-11)-2022	6.65	6.5 – 8.5
2	Taste	Hazen	IS: 3025 (P-7)-1984	Agreeable	Agreeable
3	Colour	Hazen	IS: 3025 (P-4)-1983	BLQ(LOQ-5.0)	5 Max.
4	Odour	-	IS: 3025 (P-5)-1983	Agreeable	Agreeable
5	Turbidity	NTU	IS: 3025 (P-10)-1984	BLQ(LOQ-1.0)	1 Max.
6	Total Dissolved Solid (TDS)	mg/l	IS: 3025 (P-16)-1984	112	500 Max.
7	Chloride (Cl)	mg/l	IS: 3025 (P-32)-1988	48.5	250 Max.
8	Calcium	mg/l	IS: 3025 (P-40)-1991	12.8	75 Max.
9	Magnesium	mg/l	IS: 3025 (P-46)-1994	4.9	30 Max.
10	Total Alkalinity	mg/l	IS: 3025 (P-23)-1986	16	200 Max.
11	Total Hardness (CaCO ₃)	mg/l	IS: 3025 (P-21)-2009	52	200 Max.
12	Residual Chlorine	mg/l	IS: 3025 (P-26)-1986	BLQ(LOQ-0.2)	0.2 Min
13	Sulphate (SO ₄)	mg/l	IS: 3025 (P-24)-1986	10.3	200 Max

Auth. Signatory



GHAZIABAD TESTING LABORATORIES PVT. LTD.

Report No. : 100-230921-11

Page 2 of 2

S. No.	Parameters	Unit	Test Method	Result	Standard Limit as per IS:10500-2012
Instrumental Parameters					
14	Iron as (Fe)	mg/l	IS: 3025 (P-53)-2003	BLQ(LOQ-0.1)	1.0 Max.
15	Flouride as F	mg/l	APHA 4500 (F) 23 rd Edition	BLQ(LOQ-0.1)	0.5 Max.

Remark:- Sample meets the requirement as per specified limits laid down in IS:10500-2012, as observed for the above test parameters only.

Note:- BLQ-Below the Limit of Quantification , LOQ-Limit of Quantification.

*****End of Report*****

Note:

- ❖ This Test report conforms to above test parameters only submitted for testing.
- ❖ Decision Rule applied- Yes/No UM ±
- ❖ The sample description is not verified in all cases and is given as described by the customer.
- ❖ Samples not drawn by us and the analysis conducted as received basis unless specified otherwise.
- ❖ Tested sample will be disposed off after 30 days from the date of issue of test report unless until specified by customer.
- ❖ Complaints about this report should be communicated in writing within seven days of issue date of this report.
- ❖ This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and shall not be used in the advertising media without our prior permission from the Director.
- ❖ Laboratory shall maintain the confidentiality of all information related to the samples & Test Reports.



Singh
Principal
DPS Sector-122
Noida-UP

